



A-MARK
Product Certification Mark



ACB 045

PRODUCT CERTIFICATE OF CONFORMITY

Certification Scheme Type 5

This is to certify that the product and certificate holder detailed here-on complied to the Certification Requirements of ANQAS Certification Sdn. Bhd.

POLYETHYLENE (PE) PIPES FOR WATER SUPPLY AND DRAINAGE AND SEWERAGE UNDER PRESSURE

is found to comply with

MS 1058-2: 2023

Certificate Holder : **CHEZY INDUSTRIES SDN. BHD.**
NO. 22, JALAN URANUS AK U5/AK,
TAMAN SUBANG IMPIAN, SEKSYEN U5,
40150 SHAH ALAM,
SELANGOR DARUL EHSAN, MALAYSIA.

Product Description : *Product Description shall refer to Appendix A*

Manufacturer : **LU'AN ZHONGCAI PIPES TECHNOLOGY CO. LTD.**
NORTH OF SHOUCHUN ROAD,
LU'AN ECONOMIC AND TECHNOLOGICAL
DEVELOPMENT ZONE,
ANHUI PROVINCE,
PEOPLE'S REPUBLIC OF CHINA.

Certificate No.:
F10324

Date of Initial
Certification:
23.09.2024

Date of Issue:
14.08.2026 (A1)

Date of Expiry:
30.09.2027

Brand

Chezy

Certificate issued by:
ANQAS CERTIFICATION SDN. BHD.
201801028248 (1290274-U)
Wisma ANQAS, B2-57-59,
Jalan Sutera 1/3, Sutera Niaga 8,
Taman Sutera, 43000 Kajang,
Selangor Darul Ehsan, MALAYSIA.

Website: www.anqascertification.com
Tel : +603-3310 0031
: +603-8740 5737/9447
: +603-8740 2287

.....
Ts. AZMAN BIN IDRIS
Managing Director
ANQAS CERTIFICATION SDN. BHD.



PRODUCT CERTIFICATE OF CONFORMITY

Certificate Holder : CHEZY INDUSTRIES SDN. BHD.

Product Description

Pressure Rating	Pipe Series	Nominal Size (DN)	Material Designation
*PN16	SDR11	16, 20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	PE100

*Not For Vacuum Sewer Systems

Raw Material Compound For PE 100 : BORSAFE HE 3490 LS
Blue Compound : BORSAFE HE 3494 LS

Pressure Rating	Pipe Series	Nominal Size (DN)	Material Designation
*PN6	SDR26	75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	PE100

*Not For Vacuum Sewer Systems

Raw Material Compound For PE 100 : BORSAFE HE 3490 LS
Blue Compound : BORSAFE HE 3494 LS

Pressure Rating	Pipe Series	Nominal Size (DN)	Material Designation
*PN10	SDR17	16, 20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	PE100

*Not For Vacuum Sewer Systems

Raw Material Compound For PE 100 : BORSAFE HE 3490 LS
Blue Compound : BORSAFE HE 3494 LS

Pressure Rating	Pipe Series	Nominal Size (DN)	Material Designation
*PN12.5	SDR13.6	16, 20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630	PE100

*Not For Vacuum Sewer Systems

Raw Material Compound For PE 100 : BORSAFE HE 3490 LS
Blue Compound : BORSAFE HE 3494 LS

Certificate No. : F10324
Date of Initial Certification : 23.09.2024
Date of Issue : 14.08.2026 (A1)
Date of Expiry : 30.09.2027


.....
Ts. AZMAN BIN IDRIS
Managing Director
ANQAS CERTIFICATION SDN. BHD.

